



NOTES

1. TRENCH DAMS SHALL BE INSTALLED WHERE UTILITIES OR CONDUITS ARE INSTALLED BEYOND THE PERMEABLE BALLAST SECTION. TRENCH DAMS SHALL BE CONSTRUCTED FOR UTILITIES, WHETHER PUBLIC OR PRIVATE.
2. IF THE UTILITY PIPE/CONDUIT IS DUCTILE IRON, IT SHALL BE ENCASED IN POLYETHYLENE SLEEVE, MEETING THE REQUIREMENTS OF AMERICAN WATERWORKS ASSOCIATION (AWWA).
3. BENTONITE SHALL NOT BE ALLOWED UNDER A PAVED SURFACE.



DATE SEALED: 3/6/17

CITY OF PUYALLUP
OFFICE
of
THE CITY ENGINEER

UTILITY TRENCH DAM

DRAWN BY V STOCKMAN	CHECKED BY TED HILL	APPROVED BY MARK PALMER	REVISED BY X	DATE REVISED: XXXXXX XXXXXX XXXXXX	CITY STANDARD
FILE NAME F:\DWG\COMMON\STDS\CITY\STDS\06_MISC\06.01\06.01.10	DATE APPROVED 02/24/2017	SCALE NTS	XXXXXX XXXXXX XXXXXX	06.01.10	